

Statement of Deficiencies

1903.E.6.: Outdoor - Crawlspace

Not Met

1903.E.6.: Crawlspace and mechanical, electrical, or other hazardous equipment shall be made inaccessible to children.

Finding:

1903.E.6. Based on observations: Mechanical/electrical, or other hazardous equipment is not inaccessible to children as Specialist observed an A/C unit in the outdoor play area at 11:00 a.m. The A/C unit is just to the left as one enters the outdoor play area. The A/C unit is partially surrounded by plastic fencing only two feet in height. The A/C unit is three feet in height and can be touched by children. The A/C unit can be an electrical shock hazard.

Corrective Action Plan - S1 stated her spouse will install permanent fencing of a proper height of three to four feet to surround the A/C unit.
