

Statement of Deficiencies

1903.C.: Free of Hazards

Not Met

1903.C.: Indoor and outdoor areas shall be free of hazards.

Finding:

1903.C. Based on observations:

The indoor area was not free of hazards as the Specialist observed during the initial walk through of the center at 11:15 am, two electrical outlets in the upstairs hall were not covered. This was immediately corrected.
