Date - 01/24/2019 License # - 8386 Action Code - 25 - COMPLIANCE

Statement of Deficiencies

1901.M.: Strings and Cords

Not Met

1901.M.: Strings and cords, including but not limited to those found on equipment, window coverings, televisions and radios, shall be inaccessible to children under age 4.

Finding:

1901.M. Based on observations on 1/24/19, Strings and cords were accessible to children under age 4 in S5's classroom as evidenced by the cord from a lamp and the radio was hanging over the sink the children used in the toddlers classroom. S1 removed the lamp and placed it above the refrigerator and took the radio cord and lifted it out of the reach of the children. S5's children range from ages 2 to 3 years old.

1903.C.: Free of Hazards Not Met

1903.C.: Indoor and outdoor areas shall be free of hazards.

Finding:

1903.C. Based on observations on 1/24/19, the indoor area were not free of hazards as evidenced by in the art/science room 2 of 8 outlets did not have an outlet cover and on the outside of the classroom 1 of 2 outlets did not have an outlet cover. S1 placed covers in the outlets during the visit.