

Statement of Deficiencies

7327-C: Construction Hazards

Not Met

7327-C: 5327.C. Construction, remodeling, or alterations of structures shall be done in such a manner as to prevent hazards or unsafe conditions (fumes, dust, safety hazards).

Finding:

7327-C Based on observations: Construction, remodeling, or alterations of structures were not done in such a manner as to prevent hazards or unsafe conditions (fumes, dust, safety hazards) as specialists observed the fencing near the back exit to the additional buildings has several feet of the metal fencing rolled up on one side with jagged metal edges sticking out and within reach of the children on the play yard. Also, the metal pole joining the fence is sticking outward. On the infant/toddler play yard the metal fencing is also rolled up on one side as it is in the process of being constructed and there is a approximately a foot between the building and the fencing in which a child could get stuck behind the fencing.
