

## ***Statement of Deficiencies***

### **5323-B.4: Outdoor - Crawlspace**

**Not Met**

5323.B.4. Crawlspace and mechanical, electrical, or other hazardous equipment shall be made inaccessible to children.

#### **Finding:**

7323.B.4. (OLD TAG #5323.B.4.) Crawlspace and mechanical, electrical, or other hazardous equipment is not inaccessible to children.

#### **FINDINGS INCLUDE:**

\*SPECIALIST OBSERVED THAT THERE ARE 8 AIR CONDITIONING UNITS THAT ARE ACCESSIBLE ALONG THE PATHWAY THE CHILDREN WALK ALONG TO GET OUT TO THE PLAYGROUND. A WORK ORDER TO FIX THIS HAS BEEN PUT IN TO THE SCHOOL BOARD MAINTENANCE OFFICE AND THEY PLAN TO HAVE IT FIXED AFTER THE NEW BUILDING IS COMPLETED.

---