

Statement of Deficiencies

1903-E.6: Outdoor - Crawlspace

Not Met

1903-E.6: Crawlspace and mechanical, electrical, or other hazardous equipment shall be made inaccessible to children.

Finding:

1903-E.6 Based on observations: Crawlspace and mechanical, electrical, or other hazardous equipment is not inaccessible to children as the building has settled creating a crawl space in the play yard that is accessible to the children.
