

Statement of Deficiencies

1903.C.: Free of Hazards

Not Met

1903.C.: Indoor and outdoor areas shall be free of hazards.

Finding:

1903.C. Based on observation on 5/15/2019, the indoor area were not free of hazards as Specialist observed a black box fan sitting on two small toy boxes near the wall by the sink in Hooter B. Specialist noted upon entering the classroom noted that there was no air circulating and it was hot. Specialist was advised by S1 that the air had not been working since 4/30/2019. S1 stated that the part that is needed is in but was advised by the repair company that it would be fixed sometime this week. Specialist observed that the thermostat in the classroom was set to cool the room at 72 degree but the room temperature in the room was at 81 degrees .
