

Statement of Deficiencies

1903-E.5: Outdoor - Enclosed

Not Met

1903-E.5: Outdoor play space shall be enclosed with a permanent fence or other permanent barrier in a manner that protects children from traffic hazards, prevents children from leaving the premises without proper supervision, and prevents contact with animals or unauthorized persons.

Finding:

1903-E.5 Based on observations: Outdoor play space lacked enclosure with a permanent fence or other permanent barrier in a manner that protects children from traffic hazards, prevents children from leaving the premises without proper supervision, and prevents contact with animals or unauthorized persons. On 05/17/17 specialist walked around the all sides of the gate and found that the area cited on 11/17/16 had been repaired. Specialist however observed three other areas in the fence that were not in tack. When facing with back to the building, in the right far corner of the playground, specialist observed that one side (right) was not attached at the post and could be pulled down allowing a child to exit, when traveling from the right corner along the back side of the fence near the left post, specialist observed an area where the links were pulling away from the ground allowing a small hole from which a child could exit, traveling from the left rear post along the left side of the fence going towards the front of the building, specialist observed another area where the links were pulling away from the ground and where the fence was also not completely secured to the post as it can pushed up and outward.
