

## ***Statement of Deficiencies***

### **713.A: Office of Public Health, State Fire, City Fire approval**

**Not Met**

713.A: Current approvals by the Office of Public Health, Office of State Fire Marshal, City Fire (if applicable) and the Licensing Division shall be required before the expiration of an existing license.

#### **Finding:**

713.A Based on record review by the Specialist on 6/27/17 the Center lacked documentation of a current annual inspection and approval from the State Fire Marshal. The date of the last Fire Marshal Inspection was 6/14/17 and the center was cited for needing the Fire Alarm system serviced and tagged. S1 states the Center has corrected the issue and is waiting for the Fire Marshal to come back out and reinspect.

---