

Statement of Deficiencies

1903.C.: Free of Hazards

Not Met

1903.C.: Indoor and outdoor areas shall be free of hazards.

Finding:

1903.C. Based on observations: The indoor areas were not free of hazards as Specialist observed peeling paint in rooms 121, 122, 119, 114, 112, and 111. Specialist also observed cracked plastic electrical outlet face plates with missing pieces in rooms 114 and 119. This was observed at 9:30 a.m. during the walk through inspection on 7/16/19. S3 stated the center will be closed for the next three weeks for summer vacation, at which time maintenance staff will be completing needed painting. The electrical outlet face plates were replaced before Specialist's departure.
