

Statement of Deficiencies

1903-C: Free of Hazards

Not Met

1903-C: Indoor and outdoor areas shall be free of hazards.

Finding:

1903-C Based on Observations by the Specialist on 7/17/17 the Center outdoor play area was not free of hazards as evidenced of an open natural gas meter on the playground area that is accessible by the children. The gas meter is next to the play equipment and not fenced off from the children while they are on the playground. The Specialist advised S1 to have a fence installed around the gas meter to prevent children from accessing the meter during outdoor playtime.
