

Statement of Deficiencies

1903.C.: Free of Hazards

Not Met

1903.C.: Indoor and outdoor areas shall be free of hazards.

Finding:

1903.C.: Free of Hazards: Based on observation on 7/17/19 at approximate 11:20 AM the indoor area were not free of hazards as evidenced by the Specialist observing that there were 2 outlets missing 4 plug covers, the two outlets also had cracked outlet covers which is a hazard due to the hard sharp plastic and the availability for children to stick their fingers into the outlet where exposed wires are located.
