

## ***Statement of Deficiencies***

**713.A: Office of Public Health, State Fire, City Fire, Office of Early Childhood approval**

**Not Met**

713.A: Current approvals by the Office of Public Health, Office of State Fire Marshal, City Fire (if applicable), Office of Early Childhood and the Licensing Division shall be required before the expiration of an existing license.

**Finding:**

713.A Based on record review: The Provider lacked documentation of a current annual inspection and approval from State Fire Marshal. Although the center had a certificate from the State Fire Marshal, the report indicated that the center was not in compliance again at the follow up visit dated 8/3/17. The center installed a window in the infant room but is not large enough. Other deficiencies were also cited at the follow up that need to be corrected.

---