

Statement of Deficiencies

1903.E.3.: Outdoor - Direct Exit

Not Met

1903.E.3.: Outdoor play space shall be available through a direct exit from the center into the outdoor play space or shall be attached to the center in a manner that ensures children are continuously protected by a permanent fence or other permanent barrier while going to and from the center to the outdoor play space.

Finding:

1903.E.3. Based on observations: The Outdoor play space lacked a direct exit from the center into the outdoor play space or shall be attached to the center in a manner that ensures children are continuously protected by a permanent fence or other permanent barrier while going to and from the center to the outdoor play space.
