

Statement of Deficiencies

1903-E.5: Outdoor - Enclosed

Not Met

1903-E.5: Outdoor play space shall be enclosed with a permanent fence or other permanent barrier in a manner that protects children from traffic hazards, prevents children from leaving the premises without proper supervision, and prevents contact with animals or unauthorized persons.

Finding:

1903-E 5: Outdoor-enclosed, based on observation, Outdoor play space lacked enclosure with a permanent fence or other permanent barrier in a manner that protects children from traffic hazards, prevents children from leaving the premises without proper supervision, and prevents contact with animals or unauthorized persons. Gate on small playground does not latch and can be easily pushed open.

1903-E.6: Outdoor - Crawlspace

Not Met

1903-E.6: Crawlspace and mechanical, electrical, or other hazardous equipment shall be made inaccessible to children.

Finding:

1903-E-6: Outdoor-Crawlspace. Based on observation, Crawlspace and mechanical, electrical, or other hazardous equipment is not inaccessible to children as the fencing that is around the bottom of the center has come unattached allowing children possible access to underneath the center.
