

Statement of Deficiencies

1903.C.: Free of Hazards

Not Met

1903.C.: Indoor and outdoor areas shall be free of hazards.

Finding:

1903.C. Based on observations/interview on 9/23/2019, at 9:59 am, the indoor area was not free of hazards. Specialist entered classroom#5 located in Hooter C building and noted that the classroom was hot. Specialist observed 15 (4 year old) children in the classroom along with one staff. The thermostat was observed to be set at 60 degrees with the room temperature for the room giving a reading of 70. There was no air circulating in the classroom. S1 attempted to turn on the unit but it did not come on. Per S1's statement, the unit was working on 9/20/2019. S1 placed a call to have the unit looked at while Specialist was present to have the unit worked on and was advised that someone would be out to work on the unit on 9/23/2019. S1 stated that the children from that classroom would be split up into other classrooms until the unit is fixed.
